

BOOTH
NUMBER

Oshkosh Fire Department 2010 Sawdust Days Cook Tent Requirements

The tents must be fire retardant. (N.F.P.A. 701)

There shall be No Smoking and signs posted.

Fire extinguisher.

A 2-½ pound Dry Chemical (2A) fire extinguisher is required.

A “K” fire extinguisher is needed for all grease or oil cooking.

Do not block fire extinguishers, exit ways, or exit doors; do not cover exit signs.

The cook tent shall not be located within 20 feet of buildings, other tents, or parked cars.

No public access into the cook tent unless approved by the Oshkosh Fire Department.

Sawdust or wood chips inside tents shall be kept damp.

Heating and cooking

Heating equipment shall be designed to vent to the outside air.

Cooking and heating equipment shall not be located within 10 feet of exits or combustible materials.

Electrical cooking and heating equipment shall comply with the ICC *Electrical Code*.

Portable LP tanks shall not be used for securing tents.

Portable LP-gas containers less than 500 gallons shall have a minimum separation of at least 10 feet.

Fire Protection Certification

The undersigned certifies that _____
(COMPANY NAME)

(COMPANY ADDRESS)

has made its exhibit and display materials fire-retardant by treating them with

_____ on _____
(NAME OF FIRE-RETARDANT TREATMENT) (DATE OF TREATMENT)

(SIGNATURE OF COMPANY REPRESENTATIVE)

(NAME OF COMPANY REPRESENTATIVE – PRINTED OR TYPEWRITTEN)

NOTE:

This not a complete listing of the fire regulations, only an example of commonly violated regulations. The Fire Chief may modify the above regulations. The Fire Chief has the ultimate authority over regulations by Local & State Law.

**BOOTH
NUMBER**

Oshkosh Fire Department 2010 Sawdust Days Cook Tent Requirements

<http://www.ci.oshkosh.wi.us/Fire/prevention.htm> E-mail sschrottky@ci.oshkosh.wi.us