

BOOTH NUMBER

OSHKOSH FIRE DEPARTMENT

2010 "Winnebago County Fair"
Inside Building Vendor Violations

Do not block fire extinguishers, exit ways, or exit doors; do not cover exit signs.

Booths and tables curtains, table drapes or decorations must be fire retardant.
(N.F.P.A. 701)

No plastic table drapes

Table draping must treated by the manufacturer or exhibitor.

Fire protection certificate must be submitted.

Natural vegetation is only allowed as decorations if treated with fire retardant.

Spark producing devices are allowed subject to the approval of the Fire Chief.
(A 2-1/2 pound Dry Chemical (2A) fire extinguisher is required.)

No open flame or open flame devices are allowed.

No welding, soldering, or brazing is allowed.

Vehicles or trailers on display

Vehicles must contain less than 5 gallons of fuel

The fuel fill cap must be taped over

The battery must be disconnected

Fueled accessories (generators, blowers, chain saws, etc.)

Must not be running or operable

Batteries disconnected if applicable

Little or no fuel in the fuel tank

The fuel tank must be taped over

The Fire Chief must approve display or use of flammable and or combustible liquid.

PLEASE RETURN TO SHOW OFFICE WHEN COMPLETED

Fire Protection Certification

The undersigned certifies that _____
(COMPANY NAME)

(COMPANY ADDRESS)

has made its exhibit and display materials fire-retardant by treating them with

_____ on _____
(NAME OF FIRE-RETARDANT TREATMENT) (DATE OF TREATMENT)

(SIGNATURE OF COMPANY REPRESENTATIVE)

(NAME OF COMPANY REPRESENTATIVE – PRINTED OR TYPEWRITTEN)